

**ADDENDUM #1**

**to the**

**Bolinas Community Public Utility District's**

**EAST TANK REHABILITATION PROJECT**

**June 22, 2018**

The Bolinas Community Public Utility District (BCPUD) issues this Addendum #1 to the original Notice to Bidders and accompanying Contract Documents issued on June 6, 2018. This Addendum #1 addresses questions that the BCPUD has received in writing to date from potential bidders.

Question No. 1: A Potential Bidder requested that the licensure required for this project be revised to include a Class A and C-33 license.

Answer No. 1: The licensure requirements to Bid on this Project (see Project Manual, Document 00100-2, Article 8) are hereby revised to add a Class A - General Engineering Contractor license as a requirement to Bid. The Project Manual already specifies a C-33 license as a requirement to Bid.

Question No. 2: Is there a soils report with borings for the Bolinas Tank Project?

Answer No. 2: No. Potential Bidders may reference publically-available geology reports and maps covering the East Tank Project Site and Bolinas vicinity, including U.S. Geological Survey Open-File Report 97-456 (<http://pubs.er.usgs.gov/publication/ofr97456>) (<https://pubs.usgs.gov/of/1997/of97-456/pr-map.pdf>) (<https://pubs.usgs.gov/of/1997/of97-456/pr-geo.txt>)

Question No. 3: Does BCPUD have the load numbers for the anchors?

Answer No. 3: Yes. The Design Load for each anchor rod is 22.9 kips.

BCPUD reserves the right, in its sole discretion, to terminate the request for bids process at any point in the process and to reject any and all Proposals and Bids.

This Addendum #1 shall not create any legal rights or responsibilities. Except as described in this Addendum, all terms of this request shall be as set forth in the Notice to Bidders and Contract Documents.